

Corrigendum-02

Tender Notice No.: RRU/CDFM/RSV Hostel/2023-24/05						
Date of Issue of Tender : 10.11.2023 at 15:00 Hrs						
Name of Work : Construction of Hostel Block (G+2) for Raksha Shakti Vidhyalay at RRU Campus, Lavad, Gandhinagar						
Name of Client : The Registrar, Rashtriya Raksha University, Lavad, Dehgam						
Response of Pre Bid Queries						
S. N	Page No.	Clause No.	Volume	As per Tender	Quarries	Response / Clarification
GENERAL						
1	9	TECHNICAL PART	NIT TENDER	Time Allowed: 06 Months	Time Allowed: 06 Months Please clarify	Time Allowed: 09 Months
				CPWD Specification	Kindly confirm that an Undertaking would be accepted confirming the given Specification of CPWD in Tender documents.	Accepted
2	14	TECHNICAL PART	NIT TENDER	Rashtriya Raksha University, Lavad, Gandhinagar	Name for the Tender fees and EMD	The Registrar, Rashtriya Raksha University
3	176			<p>"The Electrical contractor must have completed following kind of jobs under one project head in last 3 years."</p> <ul style="list-style-type: none"> • SITC MV/LV Cabling and termination work. • SITC of all M.V. Switch gear and power panels made by CPRI approved panel vendor. • Internal wiring with PPI (Per Phase Isolation) type Distribution Boards. • SITC of external lighting like poles, cables, Timers, cable trenches etc. • Solar Power plant installation work. 	<p>We request to consider the above stated work to be completed in last 7 Years as due to Covid-19 many of the works haven't been completed, thus, for the same No Form 3A has been granted</p>	<p>"The Electrical contractor must have completed following kind of jobs under one project head in last 7 years."</p> <ul style="list-style-type: none"> • SITC MV/LV Cabling and termination work. • SITC of all M.V. Switch gear and power panels made by CPRI approved panel vendor. • Internal wiring with PPI (Per Phase Isolation) type Distribution Boards. • SITC of external lighting like poles, cables, Timers, cable trenches etc. • Solar Power plant installation work.

4					Submission of the Physical Copy by speed post/courier or by hand delivery	Submission by any means. But should be reached before the time mentioned in the NIT.
CIVIL WORK						
5	3	Section 4	Schedule B	Brick work with common burnt clay F.P.S. (non modular) bricks of class designation 7.5	Bricks of class designation 7.5 are not available in market. please suggest	The brick of class designation shall be considered 3.5 instead of 7.5 for all brick masonry work.
HVAC Work						
6	42	Section 19	Schedule B	For Item No. 19.01 to 19.08: Copper Pipe and Control Cable	We have considered Copper pipe and Control cable 10Feet beyond qty. Rates will be extra.	Quantity for Additional Pipes shall be considered in Item no 19.10
7	42	Section 19	Schedule B	For Item No. 19.09 : MS Stand	Kindly clarify. MS stand including in item No. 19.01 and also given in Item No. 19.09: Supply & Installation of MS Stand. Kindly clarify.	Quantity shall be considered separate item no 19.09
8	42	Section 19	Schedule B	HVAC Make of Material	Mentioned in BOQ "Premium Cat." kindly clarify.	Mitsubishi, Daikin
ELV Work						
9	37-38	Section 17	Schedule B	Item No. 17.03, MR-78: Providing License for CCTV for 50 Units	We have considered the license of Camera Make	The university has decided not execute the BoQ item No. 17.03
FFTG						
10	41	Section 18	Schedule B	Legal Fees of NOC (Item no -18.26)	Legal Fees of NOC in client (RRU) scope.	All liaison Charges shall be borne by the Contractor